

## SECTION 5

## 5 Participant Connection Lines

---

Eleven service extension connection lines have been identified to serve 32 potential Regional System participants in the probable study boundary established in the Master Plan. Two connection lines have been identified to serve four potential Regional System participants in the possible study boundary established in the Master Plan. An additional ten potential participants are identified as direct connection customers in the probable study boundary that do not require significant service extensions from the existing Gillette water system.

An overall system map has been developed to show general improvements to establish the Regional System connections to the potential participants (see “Overall System Map”). A map of the locations of each of the mapbook sheets was developed to show where each potential participant is located (see “Overall Location Map”). The existing system information presented in this section from Inventory Survey forms is presented in Table 6. The future connection information developed in the Study is presented in Table 7. The connection lines are presented in detail, following these summary tables.



**(THIS PAGE LEFT BLANK INTENTIONALLY)**

**TABLE 6 SUMMARY OF POTENTIAL PARTICIPANT'S EXISTING WATER SYSTEM FACILITIES**

| Potential Regional Participant                               | Comments  | Level of Interest | Inventory Form                             | Existing Water Taps | Future Water Taps | Water Meters? | Disinfection Method | System Structure                   | System Reliability | System Age (years) | Annual Usage (gallons) | Peak Day Summer (gallons) | Peak Day Winter (gallons) | Other Users                               | Fire Protection? | Available Fire Flow (gpm) | Standby Power? | Operating Pressure | Optimum Pressure                           | System Studies? | Water Quality Data? | Tank 1 Elevation (ft) | Tank 2 Elevation (ft) | Tank 3 Elevation (ft) |  |
|--|---|-------------------|--|---------------------|-------------------|---------------|---------------------|------------------------------------|--------------------|--------------------|------------------------|---------------------------|---------------------------|---|------------------|---------------------------|----------------|--------------------|--|-----------------|---------------------|-----------------------|-----------------------|-----------------------|--|
| AMERICAN ROAD WATER AND SEWER                                |   | Unknown           | American Road Water @ Sewer District.pdf   | 70                  | 0                 | Yes           | Chlorine Gas        | Improvement & Service              | Fair               |                    | 10,709,000             | 58,174                    | 28,516                    |   | No               |                           | No             | 50 to 60           |  | No              | Yes                 | 4530.534              |                       |                       |  |
| ANTELOPE MOBILE HOME PARK                                    |   | Unknown           | Antelope Mobile Home Park.pdf              | 110                 | 0                 | No            | Sodium Hypochlorite | Private System                     |                    |                    | 16,425,000             | 51,323                    | 28,516                    |   |                  |                           |                |                    |  | No              | Yes                 | 4467.331              |                       |                       |  |
| ANTELOPE VALLEY  | Fluoride levels in well water. Antelope Valley very interested in having a part in the creation of a Regional Water System.   | Very Interested   | Antelope Valley.pdf                        | 320                 | 13                | Yes           | Chlorine Gas        | Improvement & Service              | Good               | 30                 | 44,615,000             | 600,000                   | 85,000                    | Yes - Kwik Shop, Church                   | Yes              |                           | No             | 70 to 120          |  | No              | Yes                 | 4831.848              | 4843.127              |                       |  |
| ANTELOPE VALLEY BUSINESS PARK IMPROVEMENT & SERVICE DISTRICT |   | Unknown           | Antelope Valley Bus. Park.pdf              | 5                   | 0                 | No            | Sodium Hypochlorite | Improvement & Service              | Fair               |                    | 1,883,000              | 10,806                    | 2,968                     | All Business                              | No               |                           | No             | 90                 |  | No              | Yes                 | 4651.0039             |                       |                       |  |
| BENNOT SUBDIVISION   | Privately owned system  | Interested        | Bennot.pdf                                 | 43                  | 0                 | Yes           | Chlorine Gas        | Private System                     | Good               |                    | 4,419,000              | 48,387                    | 18,322                    |   | No               |                           | No             | 60                 | 60   | No              | Yes                 | 4802.735              |                       |                       |  |
| BUCKSKIN MEADOWS SUBDIVISION                                 | Privately owned system; new system with one well and no tank or pump station  | Unknown           | Buckskin Meadows.pdf                       | 1                   | 7                 | No            | None                | Private System                     | Good               | New                | Unknown                | Unknown                   | Unknown                   |   | No               |                           | No             |                    |  | No              | No                  | No Tank               |                       |                       |  |
| CAMPBELL COUNTY AIRPORT                                      |   | Unknown           | Campbell County Airport.pdf                | 18                  | 0                 |               | Chlorine Gas        |                                    |                    |                    | 2,089,000              | 15,871                    | 8,290                     |   |                  |                           |                |                    |  |                 | Yes                 | 4342.86               |                       |                       |  |
| CEDAR HILLS WATER ASSOCIATION                                | Runs well; No water quality issues  | Unknown           | Cedar Hills Water Company.pdf              | 100                 | 0                 | No            | Chlorine Gas        | Homeowners/Water Company           | Good               | 20+                | 12,107,000             | 96,710                    | 24,258                    | None                                      | Yes              |                           | No             | 70                 | 70   | No              | Yes                 | 4599.951              | 4579.648              | 4576.656              |  |
| CENTRAL CAMPBELL COUNTY IMPROVEMENT & SERVICE DISTRICT       |   | Not Interested    | Sleepy Hollow.pdf                          | 420                 | 0                 | Yes           | Chlorine Gas        | Improvement & Service              | Good               |                    | 38,359,000             | 138,968                   | 100,258                   |   |                  |                           |                |                    |  | No              | Yes                 | 4657.205              | 4576.202              |                       |  |
| COOK ROAD WATER DISTRICT                                     |   | Unknown           | Cook Road Water District.pdf               | 70                  | 0                 | Yes           | Chlorine Gas        | Improvement & Service              | Good               |                    | 18,321,000             | 145,193                   | 18,323                    |   | Yes              |                           | No             | 20                 |  | No              | Yes                 | 4961.643              |                       |                       |  |
| COUNTRYSIDE WATER USERS                                      |   | Unknown           | Country Side.pdf                           | 160                 | 0                 | No            | Sodium Hypochlorite | Private System                     | Fair               |                    | 11,781,000             | 76,419                    | 17,000                    |   |                  |                           |                |                    |  | No              | Yes                 | 4576.736              | 4580.425              | 4564.583              |  |
| CRESTVIEW ESTATES SUBDIVISION                                | We have one well and a contract to buy water from Antelope Valley; Water quality is good.   | Interested        | Crestview Estates.pdf                      | 160                 | 0                 | Yes           | Chlorine Gas        | Water & Sewer District             | Good               | 25                 | 21,950,000             | 140,419                   | 30,032                    | No  | Yes              |                           | No             | 55                 |  | No              | Yes                 | 4752.117              |                       |                       |  |
| EIGHT MILE SUBDIVISION                                       | Finishing a water well project with WWDC and an engineering firm  | Interested        | 8-Mile.pdf                                 | 29                  | 0                 | Yes           | Chlorine Gas        | Improvement & Service              | Fair               |                    | 4,612,000              | 23,193                    | 7,580                     | No  | Yes              | 1400 GPM                  |                | 60                 | 60   | No              | Yes                 | 4868.506              |                       |                       |  |
| FORCE ROAD JOINT POWERS BOARD                                | No inventory form returned  | Unknown           | Force Road.pdf                             |                     |                   |               |                     |                                    |                    |                    |                        |                           |                           |   |                  |                           |                |                    |  |                 |                     | 4744.93               |                       |                       |  |
| FOX PARK SUBDIVISION   |   | Unknown           | Fox Park.pdf                               | 281                 | 0                 | Yes           | Chlorine Gas        | Improvement & Service              | Good               |                    | 35,000,000             | 192,903                   | 63,935                    |   | Yes              |                           |                | 60                 | 60   | No              | Yes                 | 4535.399              |                       |                       |  |
| FOX RIDGE  | Inventoried because it was on a route; no inventory form returned   | Unknown           | Fox Ridge.pdf                              |                     |                   |               |                     |                                    |                    |                    |                        |                           |                           |   |                  |                           |                |                    |  |                 |                     |                       |                       |                       |  |
| FREEDOM HILLS SUBDIVISION                                    | High fluorides in well water  | Unknown           | Freedom Hills.pdf                          | 160                 | 0                 | No            | Chlorine Gas        | Improvement & Service              | Good               |                    | 29,744,000             | 136,710                   | 71,452                    |   |                  |                           | No             | 40                 |  | No              | Yes                 | 4582.885              |                       |                       |  |
| GLORY HOLE HOMEOWNERS ASSOCIATION                            | Needs Tank - Possible easement issues   | Split Interest    | Glory Hole.pdf                             | 24                  | 0                 | No            | None                | Homeowners                         | Good               |                    | 3,194,000              | 21,097                    | 4,581                     | No  | No               |                           | No             |                    |  | No              | Yes                 |                       |                       |                       |  |
| GREEN VALLEY ESTATES IMPROVEMENT & SERVICE DISTRICT          |   | Unknown           | Green Valley Estates.pdf                   | 44                  | 0                 | No            | Sodium Hypochlorite | Improvement & Service              | Good               |                    | 9,879,000              | 73,903                    | 8,677                     | No  | Yes              |                           | No             | 20                 |  | No              | Yes                 | 4400.575              |                       |                       |  |
| HERITAGE VILLAGE WATER AND SEWER DISTRICT                    |   | Unknown           | Heritage Village.pdf                       | 232                 | 0                 | No            | Sodium Hypochlorite | Water & Sewer District             | Good               | 35                 | 31,487,500             | 292,000                   | 91,100                    | No  | Yes              | 1000 GPM                  | No             | 48-88              |  | No              | Yes                 | 4470.503              |                       |                       |  |
| HITCHING POST TRAILER COURT                                  |   | Unknown           | Hitching Post.pdf                          | 33                  | 0                 | No            | Sodium Hypochlorite | Private System                     |                    |                    |                        |                           |                           |   |                  |                           |                | 35                 |  |                 | Yes                 | 4675.151              |                       |                       |  |
| HOY MOBILE HOME PARK   |   | Unknown           | Hoy Mobile Home Park.pdf                   | 50                  | 0                 | No            | Sodium Hypochlorite | Private System                     |                    |                    | 5,705,000              | 19,258                    | 11,677                    | Yes - One Welding Shop                    | No               |                           |                | 30 - 50            |  | No              | Yes                 | 4359.68               |                       |                       |  |
| INTERSTATE INDUSTRIAL PARK                                   |   | Unknown           | Interstate Industrial Park.pdf             | 50                  | 0                 | No            | Sodium Hypochlorite | Water & Sewer District             | Fair               |                    | 3,900,000              | 15,677                    | 11,742                    | All business                              | No               |                           | No             | 30 - 50            |  | No              | Yes                 | 4506.379              |                       |                       |  |
| LAKEVIEW MOBILE HOME PARK                                    |   | Unknown           | Lakeview Mobile Home Park.pdf              | 19                  | 0                 |               | Sodium Hypochlorite | Private System                     | Fair               |                    | 1,233,000              | 4,871                     | 3,194                     | No  | No               |                           | No             | 30 - 50            |  | No              | Yes                 | 4573.534              |                       |                       |  |
| LEMASTER ENTERPRISES   | No inventory form returned  | Unknown           | Lemaster Enterprises.pdf                   |                     |                   |               |                     | Private System                     |                    |                    |                        |                           |                           |   |                  |                           |                |                    |  |                 |                     | 4523.215              | 4507.856              | 4498.076              |  |
| MEADOW SPRINGS IMPROVEMENT & SERVICE DISTRICT                | Ownership of system & tank size & additional wells; Water quality is good; We feel a regional water system would not be in the best interest of the people of Meadow Springs as well as Campbell & Crook Counties     | Not Interested    | Meadow Springs.pdf                         |                     |                   | No            | Sodium Hypochlorite | Improvement & Service              | Fair               |                    | 1,552,000              | 13,129                    | 2,519                     | No  | No               |                           | No             |                    |  | No              | Yes                 | 4567.65               |                       |                       |  |
| MEANS WATER AND SEWER DISTRICT                               |   | Unknown           | Means W&S District.pdf                     | 108                 | 0                 | Yes           | Chlorine Gas        | Water & Sewer District             |                    |                    | 30,411,000             | 139,097                   |                           |   |                  |                           |                |                    |  |                 | Yes                 | 4599.954              | 4614.264              |                       |  |
| MOHAN SUBDIVISION  | Existing private wells; no established distribution system  | Unknown           | Mohan Subdivision.pdf                      |                     |                   |               |                     |                                    |                    |                    |                        |                           |                           |   |                  |                           |                |                    |  |                 |                     |                       |                       |                       |  |
| NICKELSON FARMS WATER COMPANY                                | Water is good quality, good quality the age of the system is the only concern   | Unknown           | Nickelstons Little Farms Water Co.pdf      |                     |                   | Yes           | Chlorine Gas        | Homeowners                         | Fair               | 25+                | 19,000,000             | 143,419                   | 14,161                    | No  | Yes              |                           | No             |                    | Pressure system 80 Gravity system 30 to 60 | No              | Yes                 | 4772.542              | 4775.751              | 4773.841              |  |
| OVERBROOK SUBDIVISION  |   | Unknown           | Overbrook Subdivision.pdf                  | 23                  | 0                 | Yes           | Sodium Hypochlorite | Improvement & Service / Homeowners | Good               |                    | 4,010,000              | 13,871                    | 5,032                     | No  | No               |                           |                | 90                 | 80   | No              | Yes                 | 4738.307              |                       |                       |  |
| PEOPLES IMPROVEMENT & SERVICE DISTRICT                       |   | Unknown           | Peoples Improvement @ Service District.pdf | 52                  | 0                 | Yes           | Chlorine Gas        | Improvement & Service              |                    |                    | 9,231,000              | 64,000                    | 14,806                    |   |                  |                           |                |                    |  |                 | Yes                 | 4837.218              |                       |                       |  |
| RAFTER D HOMEOWNERS ASSOCIATION                              | Only one well   | Unknown           | Rafter D.pdf                               | 16                  | 0                 | No            | Sodium Hypochlorite | Homeowners                         | Good               |                    | 3,085,000              | 24,742                    | 4,194                     | No  | No               |                           | No             | 40                 | 40   | No              | Yes                 | 4731.052              |                       |                       |  |
| RAG COAL WEST INC/ RAWHIDE SCHOOL                            |   | Unknown           | Rag Coal West Inc Rawhide School.pdf       |                     |                   |               |                     |                                    |                    |                    |                        | 4,500                     |                           |   |                  |                           |                |                    |  |                 |                     |                       | 4372.247              |                       |  |
| RIDGEWAY COMMUNITY WELL ASSOCIATION                          | This water serves people living on 40 acres. The elevation is high and the wells had to be drilled so deeper and the cost per acres kept climbing. Installed some pipe lines to some acreages that didn't have water. | Unknown           | Ridgeway Survey.pdf                        | 18                  | 0                 | No            | Sodium Hypochlorite | Homeowners                         | Good               | 4                  |                        | 14,580                    |                           | No  | No               |                           | No             |                    | 25 to 80                                   | No              | Yes                 | 4903.859              |                       |                       |  |
| RODEO FLATS WATER DISTRIBUTION                               | Includes Graceland Improvement & Service District; a new system   | Unknown           | Rodeo Flats Water Distribution.pdf         | 32                  | 24                | Yes           | Chlorine Gas        | Private System                     | Good               | 2                  | 1,204,000              | 6,633                     | 250                       | No  | No               |                           | No             | 50                 |  | No              | Yes                 | 4627.822              |                       |                       |  |
| ROZET  | The town of Rozet, WY; existing Gillette main that serves a few users   | Unknown           | Rozet.pdf                                  |                     |                   |               |                     |                                    |                    |                    |                        |                           |                           |   |                  |                           |                |                    |  |                 |                     |                       |                       |                       |  |
| ROZET RANCHETTES   | Inventoried because it was on a route; Papers are in to make public; Not enough people on the system. Water sits in tank too long; Fairly high iron   | Unknown           | Rozet Ranchettes LLC.pdf                   |                     |                   | Yes           | Chlorine Gas        | Improvement & Service              | Good               | 1                  |                        |                           |                           | No  | No               |                           | No             | 80                 | 80   | No              | Yes                 | 4318.991              |                       |                       |  |
| SECTION 4 WATER SYSTEM, INC                                  |   | Unknown           | Section 4.pdf                              | 42                  | 0                 |               | Sodium Hypochlorite | Private System                     | Good               |                    | 2,321,000              | 7,710                     | 6,968                     | Yes, all are businesses                   | No               |                           | No             | 50                 |  | No              | Yes                 | 4371.939              |                       |                       |  |
| SOUTHFORK ESTATES  |   | Unknown           | South Fork Estates.pdf                     | 46                  | 0                 | Yes           | Chlorine Gas        | Improvement & Service              |                    |                    | 6,284,000              | 4,345                     |                           | No  | No               |                           | No             | 30 - 50            |  | No              | Yes                 | 4757.8                |                       |                       |  |
| SOUTHSIDE WELL IMPROVEMENT & SERVICE DISTRICT                | A homeowners meeting was held April 20th, 2009 to discuss this and other issues. The homeowners are interested possibly joining the regional system. Please contact operator.   | Interested        | Southside Well Imp & Serv Dis.pdf          | 19                  | 4                 | No            | Sodium Hypochlorite | Improvement & Service              | Fair               | 40                 | 2,000,000              | 34,098                    | 9,639                     | Mixed Commercial, Industrial, Residential | No               |                           | Yes            | 45                 | 50   | Yes             | Yes                 | 4528.92               |                       |                       |  |
| STONE GATE ESTATES   | Water quality is good; \$80/month base rate for 20,000 gallons, 20,000 to 30,000 is \$1/1000 gallons, 30,000 to 50,000 is \$2/1000 gallons, and 50,000 and above is \$5/1000 gallons                                  | Split Interest    | Stone Gate Estates.pdf                     | 67                  | 0                 | Yes           | Chlorine Gas        | Improvement & Service              | Good               |                    | 14,456,000             | 103,032                   | 16,903                    | No  | No               |                           | No             | 50                 |  | No              | Yes                 | 4876.432              | 4866.675              |                       |  |
| STROUP TRAILER COURT   |   | Unknown           | Stroups Trailer Court.pdf                  | 36                  | 0                 | No            | Sodium Hypochlorite | Private System                     |                    |                    |                        |                           |                           |   |                  |                           |                |                    |  |                 | Yes                 | 4531.856              |                       |                       |  |
| WARD CREEK LANDOWNERS ASSOCIATION                            |   | Unknown           | Ward Creek.pdf                             | 26                  | 2                 | No            | Sodium Hypochlorite | Improvement & Service              | Fair               | 28                 |                        | 30,000                    | 15,000                    | Stock watering                            | Yes              |                           | No             | 50 - 70            | 70   | No              | Yes                 |                       |                       |                       |  |
| WESSEX IMPROVEMENT & SERVICE DISTRICT                        | Water is high in iron and sodium; reliability of the well which was drilled in 1979 is a concern, cost would be prohibitive to participation in regional system   | Unknown           | Wessex Improvement & Service District.pdf  | 7                   | 0                 | No            | None                | Improvement & Service              | Good               | 30                 | 1,000,000              | 8,000                     | 3,000                     | No  | No               |                           | No             | 35 - 70            | 50   | Yes             | Yes                 | 4271.361              |                       |                       |  |
| WESTRIDGE WATER USERS ASSOCIATION                            |   | Unknown           | Westridge Survey.pdf                       | 68                  | 0                 | Yes           | Sodium Hypochlorite | Homeowners Assoc.                  | Good               |                    |                        |                           |                           | No  | Yes              |                           | No             |                    |  | No              | Yes                 | 4676.607              | 4678.726              | 4683.177              |  |
| WRANGLER ESTATES   | Need to increase the gal/min of production capability and replace #2 well so either well can produce peak water demand  | Not Interested    | Wrangler Estates Survey.pdf                | 87                  | 99                | No            | Chlorine Gas        | Privately Owned Public Utility     | Good               | 5                  | 18,236,671             | 155,000                   | 25,000                    | 3 if zoned, shops, bathrooms and office   | No               |                           | Yes            | 45 to 70           | 60   | No              |                     |                       |                       |                       |  |

(THIS PAGE LEFT BLANK INTENTIONALLY)

**TABLE 7 SUMMARY OF POTENTIAL PARTICIPANT'S FUTURE CONNECTIONS**

| Potential Regional Participant                               | Service Boundary | Type of Service | Interim Class of Service | Future Class of Service | Connection Size (inches) | Average Day Demand (gpm) | Maximum Day Demand (gpm) | Peak Hour Demand (gpm) | Preferred Delivery Point                 | Estimated Pressure at Delivery Point (psi) | Dedicated Waterline (lf) | Shared Waterline (lf) | Master Meter Size (inches) | Service Isolation Valve | Altitude Valve | New Pump Station | New Storage Tank | New Chlorine Booster Station |
|--|------------------|-----------------|--------------------------|-------------------------|--------------------------|--------------------------|--------------------------|------------------------|--|--|--------------------------|-----------------------|----------------------------|-------------------------|----------------|------------------|------------------|------------------------------|
| AMERICAN ROAD WATER AND SEWER                                | Probable         | Type 1          | Class D                  | Class E                 | 6-inch                   | 20                       | 40                       | 64                     | Existing Storage Tank                    | 100 psi                                    | 750                      | 11,000                | 4                          | Y                       | Y              | N                | N                | N                            |
| ANTELOPE MOBILE HOME PARK                                    | Probable         | Type 2          | Class C                  | Class G                 | 8-inch                   | 31                       | 36                       | 58                     | Direct Connection to Distribution System | 110 psi                                    | 100                      | 0                     | Individual Service Meters  | Y                       | N              | N                | N                | N                            |
| ANTELOPE VALLEY  | Probable         | Type 1          | Class B                  | Class B                 | 12-inch                  | 85                       | 434                      | 694                    | Existing Storage Tank                    | 15 psi                                     | 7,560                    | 350                   | 8                          | Y                       | Y              | Y                | N                | N                            |
| ANTELOPE VALLEY BUISNESS PARK IMPROVEMENT & SERVICE DISTRICT | Probable         | Type 1          | Class D                  | Class F                 | 8-inch                   | 4                        | 8                        | 13                     | Existing Storage Tank                    | 65 psi                                     | 930                      | 350                   | 6                          | Y                       | Y              | N                | N                | N                            |
| BENNROR SUBDIVISION  | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 8                        | 34                       | 54                     | Existing Storage Tank                    | 150 psi                                    | 1,200                    | 14,800                | 4                          | Y                       | Y              | N                | N                | N                            |
| BUCKSKIN MEADOWS SUBDIVISION                                 | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 4                        | 10                       | 16                     | New Storage Tank                         | 100 psi                                    | 3,000                    | 4,000                 | 4                          | Y                       | Y              | Y                | Y                | N                            |
| CAMPBELL COUNTY AIRPORT                                      | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 4                        | 11                       | 18                     | Existing Storage Tank                    | 80 psi                                     | 6,550                    | 19,150                | 4                          | Y                       | Y              | N                | N                | N                            |
| CEDAR HILLS WATER ASSOCIATION                                | Probable         | Type 1          | Class D                  | Class F                 | 8-inch                   | 23                       | 67                       | 107                    | Existing Storage Tank                    | 140 psi                                    | 5,330                    | 0                     | 6                          | Y                       | Y              | N                | N                | N                            |
| CENTRAL CAMPBELL COUNTY IMPROVEMENT & SERVICE DISTRICT       | Probable         | Type 1          | Class B                  | Class B                 | 8-inch                   | 73                       | 97                       | 155                    | Existing Storage Tank                    | 90 psi                                     | 1,550                    | 0                     | 6                          | Y                       | Y              | N                | N                | N                            |
| COOK ROAD WATER DISTRICT                                     | Probable         | Type 2          | Class D                  | Class F                 | 8-inch                   | 35                       | 101                      | 162                    | Existing Storage Tank                    | 80 psi                                     | 16,000                   | 15,400                | 6                          | Y                       | Y              | N                | N                | N                            |
| COUNTRYSIDE WATER USERS                                      | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 22                       | 53                       | 85                     | Existing Storage Tank                    | 55 psi                                     | 5,850                    | 350                   | 4                          | Y                       | Y              | N                | N                | N                            |
| CRESTVIEW ESTATES SUBDIVISION                                | Probable         | Type 1          | Class B                  | Class B                 | 8-inch                   | 42                       | 98                       | 157                    | Existing Storage Tank                    | 15 psi                                     | 1,450                    | 0                     | 6                          | Y                       | Y              | N                | N                | N                            |
| EIGHT MILE SUBDIVISION                                       | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 9                        | 16                       | 26                     | Existing Storage Tank                    | 125 psi                                    | 10,800                   | 15,400                | 4                          | Y                       | Y              | N                | N                | N                            |
| FORCE ROAD JOINT POWERS BOARD                                | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 17                       | 41                       | 66                     | Existing Storage Tank                    | 130 psi                                    | 2,700                    | 2,165                 | 4                          | Y                       | Y              | N                | N                | Y                            |
| FOX PARK SUBDIVISION   | Probable         | Type 2          | Class C                  | Class G                 | -                        | 67                       | 134                      | 214                    | Direct Connection to Distribution System | -  | -                        | -                     | Individual Service Meters  | -                       | -              | -                | -                | -                            |
| FOX RIDGE  | Probable         | Type 2          | Class A                  | Class E                 | 8-inch                   | 15                       | 36                       | 58                     | Existing Storage Tank                    | 50 psi                                     | 24,900                   | 0                     | 4                          | Y                       | Y              | N                | N                | N                            |
| FREEDOM HILLS SUBDIVISION                                    | Probable         | Type 1          | Class D                  | Class E                 | 8-inch                   | 57                       | 95                       | 152                    | Existing Storage Tank                    | 100 psi                                    | 50                       | 7,200                 | 6                          | Y                       | Y              | N                | N                | N                            |
| GLORY HOLE HOMEOWNERS ASSOCIATION                            | Possible         | Type 2          | Class A                  | Class E                 | 6-inch                   | 6                        | 15                       | 24                     | New Storage Tank                         | 45 psi                                     | 2,200                    | 45,400                | 4                          | Y                       | Y              | N                | Y                | Y                            |
| GREEN VALLEY ESTATES IMPROVEMENT & SERVICE DISTRICT          | Possible         | Type 2          | Class A                  | Class E                 | 6-inch                   | 19                       | 51                       | 82                     | Existing Storage Tank                    | 50 psi                                     | 7,500                    | 45,400                | 4                          | Y                       | Y              | N                | N                | N                            |
| HERITAGE VILLAGE WATER AND SEWER DISTRICT                    | Probable         | Type 2          | Class C                  | Class G                 | -                        | 60                       | 203                      | 324                    | Direct Connection to Distribution System | 80 psi                                     | -                        | -                     | Individual Service Meters  | Y                       | N              | N                | N                | N                            |
| HITCHING POST TRAILER COURT                                  | Probable         | Type 1          | Class D                  | Class E                 | 6-inch                   | 21                       | 50                       | 80                     | Existing Storage Tank                    | 45 psi                                     | 1,150                    | 0                     | 4                          | Y                       | Y              | N                | N                | N                            |
| HOY MOBILE HOME PARK   | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 11                       | 13                       | 21                     | Existing Storage Tank                    | 80 psi                                     | 500                      | 18,650                | 4                          | Y                       | Y              | N                | N                | N                            |
| INTERSTATE INDUSTRIAL PARK                                   | Probable         | Type 2          | Class C                  | Class G                 | -                        | 7                        | 11                       | 18                     | Direct Connection to Distribution System | -  | -                        | -                     | Individual Service Meters  | -                       | -              | -                | -                | -                            |
| LAKEVIEW MOBLE HOME PARK                                     | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 2                        | 4                        | 7                      | Existing Storage Tank                    | 90 psi                                     | 550                      | 2,700                 | 4                          | Y                       | Y              | N                | N                | N                            |
| LEMASTER ENTERPRISES   | Probable         | Type 2          | Class C                  | Class G                 | 8-inch                   | 5                        | 13                       | 21                     | Direct Connection to Distribution System | 90 psi                                     | 1,050                    | 350                   | Individual Service Meters  | Y                       | N              | N                | N                | N                            |
| MEADOW SPRINGS IMPROVEMENT & SERVICE DISTICT                 | Probable         | Type 1          | Class D                  | Class E                 | 6-inch                   | 3                        | 9                        | 14                     | Existing Storage Tank                    | 110 psi                                    | 8,200                    | 11,000                | 4                          | Y                       | Y              | N                | N                | N                            |
| MEANS WATER AND SEWER DISTRICT                               | Probable         | Type 2          | Class D                  | Class E                 | 8-inch                   | 58                       | 97                       | 155                    | Existing Storage Tank                    | 80 psi                                     | 2,300                    | 8,300                 | 6                          | Y                       | Y              | N                | N                | N                            |
| MOHAN SUBDIVISION  | Probable         | Type 2          | Class G                  | Class G                 | 8-inch looped            | 189                      | 453                      | 725                    | Direct Connection to Distribution System | 80 psi                                     | 3,900                    | 0                     | Individual Service Meters  | Y                       | N              | N                | N                | N                            |
| NICKELSON FARMS WATER COMPANY                                | Probable         | Type 1          | Class D                  | Class E                 | 8-inch                   | 36                       | 100                      | 160                    | Existing Storage Tank                    | 50 psi                                     | 7,800                    | 20,000                | 6                          | Y                       | Y              | N                | N                | N                            |
| OVERBROOK SUBDIVISION  | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 8                        | 10                       | 16                     | Existing Storage Tank                    | 180 psi                                    | 1,100                    | 14,000                | 4                          | Y                       | Y              | N                | N                | N                            |
| PEOPLES IMPROVEMENT & SERVICE DISTRICT                       | Probable         | Type 2          | Class C                  | Class G                 | 6-inch                   | 18                       | 45                       | 72                     | Direct Connection to Distribution System | 50 psi                                     | 1,400                    | 0                     | Individual Service Meters  | Y                       | N              | Y                | N                | N                            |
| RAFTER D HOMEOWNERS ASSOCIATION                              | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 6                        | 17                       | 27                     | Existing Storage Tank                    | 200 psi                                    | 350                      | 0                     | 4                          | Y                       | Y              | N                | N                | N                            |
| RAG COAL WEST INC/ RAWHIDE SCHOOL                            | Possible         | Type 2          | Class A                  | Class E                 | 6-inch                   | 1                        | 3                        | 5                      | Existing Storage Tank                    | 70 psi                                     | 1,300                    | 18,100                | 4                          | Y                       | Y              | N                | N                | Y                            |
| RIDGEWAY COMMUNITY WELL ASSOCIATION                          | Possible         | Type 2          | Class A                  | Class E                 | 6-inch                   | 4                        | 10                       | 16                     | Existing Storage Tank                    | 110 psi                                    | 35,770                   | 0                     | 4                          | Y                       | Y              | N                | N                | N                            |
| RODEO FLATS WATER DISTRIBUTION                               | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 2                        | 8                        | 13                     | Existing Storage Tank                    | 115 psi                                    | 5,850                    | 17,300                | 4                          | Y                       | Y              | N                | N                | N                            |
| ROZET  | Probable         | Type 1          | Class E                  | Class E                 | 8-inch                   | 45                       | 108                      | 173                    | New Storage Tank                         | 240 psi                                    | 500                      | 11,900                | 6                          | Y                       | Y              | N                | Y                | Y                            |
| ROZET RANCHETTES   | Probable         | Type 1          | Class D                  | Class E                 | 6-inch                   | 20                       | 47                       | 75                     | Existing Storage Tank                    | 220 psi                                    | 200                      | 0                     | 4                          | Y                       | Y              | N                | N                | N                            |
| SECTION 4 WATER SYSTEM, INC                                  | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 4                        | 6                        | 10                     | Existing Storage Tank                    | 80 psi                                     | 800                      | 18,650                | 4                          | Y                       | Y              | N                | N                | N                            |
| SOUTHFORK ESTATES  | Probable         | Type 2          | Class D                  | Class E                 | 6-inch                   | 12                       | 29                       | 46                     | Existing Storage Tank                    | 170 psi                                    | 2,700                    | 0                     | 4                          | Y                       | Y              | N                | N                | N                            |
| SOUTHSIDE WELL IMPROVEMENT & SERVICE DISTRICT                | Probable         | Type 2          | Class C                  | Class G                 | 8-inch                   | 4                        | 29                       | 46                     | Direct Connection to Distribution System | 100 psi                                    | 100                      | 0                     | Individual Service Meters  | Y                       | N              | N                | N                | N                            |
| STONE GATE ESTATES   | Probable         | Type 2          | Class D                  | Class E                 | 8-inch                   | 28                       | 72                       | 115                    | Existing Storage Tank                    | 120 psi                                    | 1,330                    | 0                     | 6                          | Y                       | Y              | N                | N                | N                            |
| STROUP TRAILER COURT   | Probable         | Type 2          | Class C                  | Class G                 | 8-inch                   | 16                       | 38                       | 61                     | Direct Connection to Distribution System | 90 psi                                     | 300                      | 0                     | Individual Service Meters  | Y                       | N              | N                | N                | N                            |
| WARD CREEK LANDOWNERS ASSOCIATION                            | Probable         | Type 1          | Class D                  | Class F                 | 8-inch                   | 9                        | 21                       | 34                     | Existing Storage Tank                    | 180 psi                                    | 18,700                   | 11,900                | 6                          | Y                       | Y              | N                | N                | N                            |
| WESSEX IMPROVEMENT & SERVICE DISTRICT                        | Probable         | Type 1          | Class D                  | Class E                 | 6-inch                   | 2                        | 6                        | 10                     | Existing Storage Tank                    | 50 psi                                     | 1,670                    | 0                     | 4                          | Y                       | Y              | N                | N                | Y                            |
| WESTRIDGE WATER USERS ASSOCIATION                            | Probable         | Type 2          | Class C                  | Class G                 | -                        | 21                       | 50                       | 80                     | Direct Connection to Distribution System | -  | -                        | -                     | Individual Service Meters  | -                       | -              | -                | -                | -                            |
| WRANGLER ESTATES   | Probable         | Type 2          | Class D                  | Class E                 | 8-inch                   | 35                       | 108                      | 173                    | Existing Storage Tank                    | 115 psi                                    | 6,170                    | 6,030                 | 6                          | Y                       | Y              | N                | N                | N                            |

(THIS PAGE LEFT BLANK INTENTIONALLY)